

No. D - 3688/17

INSPECTION CERTIFICATE

Ref : Request letter from the Principal, Vidyaniketan Public School, Payyoli,
dated 09.05.2017.

.....

We have inspected Vidyaniketan Public School, Payyoli and the following
Inspection report is issued:-


They have installed sufficient number of the Fire extinguishers which are in good
working condition.

Fire exit and other staircases should always be properly kept so as to ensure the
smooth and fast evacuation of students in emergency situations Exits should not be
locked or blocked in any manner.

Sufficient Quantity of water / water sources have to be ensured always for fire
fighting purpose.

Proper and frequent training should have to be given to the teachers, students and
staff in building fire safety and also in operating fire fighting equipments and School
Mock drills must be conducted once in 6 months.

Fire protection system as per National Building code Part IV should have to be
installed for obtaining Fire NOC from this Department. But in this case, Fire NOC is not
required as per Kerala Municipality / Panchayat Building Rules.



Assistant Divisional Officer
Fire and Rescue Services,
Kozhikode.

To,
The Principal,
Vidyaniketan Public School,
Ayanikkad P.O
Payyoli